SIEMENS

Data sheet 3TH4262-5KB4

	Contactor relay, 62E, DIN EN 50011, 6 NO + 2 NC flat connector terminal DC operation 24 V DC integrated varistor
product designation	Auxiliary contactor
product type designation	3TH4
size of contactor	0
reference code according to IEC 81346-2	K
Substance Prohibitance (Date)	03/01/2017
ambient temperature during operation	-25 ... +55 °C
type of voltage of the control supply voltage	DC
control supply voltage at DC	
● rated value	24 V
design of the surge suppressor	with varistor
number of NC contacts for auxiliary contacts	2
● delayed switching	0
● lagging switching	0
● make-before-break switching	0
number of NO contacts for auxiliary contacts	6
● delayed switching	0
● leading contact	0
● make-before-break switching	0
number of CO contacts for auxiliary contacts	0
identification number and letter for switching elements	62 E
operational current at AC-15	
● at 230 V rated value	10 A
● at 400 V rated value	6 A
fastening method	screw and snap-on mounting onto 35 mm DIN rail according to DIN EN 50022
height	78 mm
width	45 mm
depth	135 mm
type of electrical connection for auxiliary and control circuit	screw-type terminals
Safety related data	
B10 value with high demand rate according to SN 31920	1 000 000; With 0.3 x Ie
T1 value for proof test interval or service life according to IEC 61508	20 a
protection class IP on the front according to IEC 60529	IP00

Certificates/ approvals

General Product Approval				Functional Safety/Safety of Machinery	Declaration of Conformity
CSA	CCC	UL	EAC	Type Examination Certificate	EG-Konf.

Declaration of Conformity	Test Certificates			other	
UKCA	Type Test Certificates/Test Report	Special Test Certificate	Miscellaneous	Miscellaneous	Confirmation

Railway

Subject to change without notice
© Copyright Siemens

Special Test Certific-
ate

Further information

Siemens has decided to exit the Russian market (see here).
https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.
Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging
https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,…)
https://www.siemens.com/ic10

Industry Mall (Online ordering system)
https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3TH4262-5KB4

Cax online generator
http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3TH4262-5KB4

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)
https://support.industry.siemens.com/cs/ww/en/ps/3TH4262-5KB4

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)
http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3TH4262-5KB4&lang=en

Characteristic: Tripping characteristics, I²t, Let-through current
https://support.industry.siemens.com/cs/ww/en/ps/3TH4262-5KB4/char

Further characteristics (e.g. electrical endurance, switching frequency)
http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3TH4262-5KB4&objecttype=14&gridview=view1

last modified: 11/21/2022

Subject to change without notice
© Copyright Siemens